

RECREATIONAL WATER FACILITY INSPECTION REPORT

WATER CLARITY

- Total alkalinity is within required range
- pH is within required range
- Free available chlorine (FAC) residual is within required range
- Total bromine residual is within required range
- Cyanurate acid concentration is at 60 mg/L or less, where appropriate
- Oxidation Reduction Potential (ORP) value is within range of 600 mV- 900 mV (if equipped with automatic sensing device)
- Facility conducts required tests at appropriate intervals, as required
- Water clarity is satisfactory
- Water is maintained free from visible matter and contamination
- Water replacement is carried out as required

RECORD KEEPING

- Daily records are completed and signed
- Other tests and records are completed and signed
- Records are retained for one year

SUPERVISION

- Safety supervision requirements are met, where applicable
- Emergency and operational procedures are implemented where required
- Admission standards process is in place for Class A pools
- Lifeguard control station requirements are met

EMERGENCY TELEPHONE AND PROCEDURE

- Emergency telephone is present, operational and tested daily
- Emergency telephone sign is posted with complete list of emergency contacts

SAFETY EQUIPMENT

- Safety equipment is available and in good repair (Pool, Spa > 3 m, Wading Pool)
- Black disc requirements are met
- Emergency stop button requirements are met
- Suction system is equipped with a vacuum relief mechanism
- Ground current leakage detecting and de-energizing devices are provided and functional, where required
- Water heater is equipped with an operational tamper-proof upper limit cut-off switch
- Hydro-massage jet fittings are equipped with timing device
- Clock is installed in a conspicuous location
- Wave action pool is equipped with a public address system and a communications system

OPERATION

- Operator is designated and trained
- Public has no access to recreational water facility when closed
- Circulation system is in good working order and in continuous operation
- Chemical feeder is provided to administer chlorine, chlorine compound or a bromine compound
- Ultraviolet light treatment system is provided, where required
- Water outlet covers are present, secure and in good repair
- Safe storage and handling of all chemicals

FACILITY GENERAL

- All components of the facility are maintained in proper working order
- Facility is kept in safe and sanitary condition
- Change rooms, washrooms and showers are kept in safe and sanitary condition
- Bathing apparel and towels are maintained in clean and sanitary manner
- Total number of bathers does not exceed maximum bather load
- No food or beverage except water is supplied or consumed within water facility
- Deck is clearly delineated from the general area
- Diving board, platform and moveable equipment requirements are met
- Requirement for entering and exiting are met

SIGNS, NOTICES AND MARKINGS

- Signage requirements
- Depth markings present in appropriate locations

HEALTH HAZARD

- The premise appears to be free from conditions that might be a health hazard